

**QUICK SPECIFICATION** APPLICATION OR TYPICAL LOCATION: PRODUCT: DRY STONE WALL SUPPLIER: CONTRACTOR TO NOMINATE - 'ALL STONEWORK SHALL BE UNDERTAKEN BY A SUITABLY QUALIFIED AND EXPERIENCED STONE MASON OR LANDSCAPE CONTRACTOR.' WALLS MUST NOT CONTAIN MORTAR JOINTS UNLESS AGREED AND TO THE SATISFACTION OF COUNCIL MATERIAL AND STONES FINISH: FIXING / FOOTING: PROVIDE 100mm CONCRETE BASE AND 50mm THICK COMPACTED CRUSHED ROCK BASE BELOW. SET ROCK DOWN TO CRUSHED ROCK BASE ADDITIONAL OPTIONS: NOT APPLICABLE AUSTRALIAN NOT APPLICABLE STANDARDS: STANDARD DRAWING CROSS REFERENCES:

-DENSE VEGETATION BUFFER TO DISCOURAGE DIRECT ACCESS TO RECONSTRUCT THE FIRST 3.0m THE WALL AND MINIMISE OF STONE WORK DAMAGE AND DISTURBANCE. SPECIFY PLANT SPECIES THAT HAVE A GROWTH CHARACTERISTIC THAT WILL NOT ADVERSELY IMPACT THE STRUCTURAL INTEGRITY OF THE ADJACENT WALL. -EXISTING DRY STONE WALL 2.5m WIDE PLANTING 1 0m OVERLAP OF DESIGNED SO AS NOT TO PLANTING OVER DETRACT FROM THE VISUAL RECONSTRUCTED WALL AMENITY/ CHARACTER

03) RECONSTRUCTED STONE WALL - PLAN
SCALE: 1:100 @A4

02 RECONSTRUCTED STONE WALL - SECTION
SCALE: 1:100 @A4

EXISTING WALL TO

BE MADE GOOD

HEIGHT OF

RECONSTRUCTED

WALL TO MATCH

EXISTING WALL

RECONSTRUCT THE FIRST

3.0m OF STONE WORK

Drawn	нк
Checked	AC, AN
Approved	JG
Date	JUNE 2023



EXTENT OF DEMOLITION VARIES ACCORDING TO PATH

WIDTH AND ANGLE

PEDESTRIAN PATH

(1.5m OR 2.5m WIDE)

STANDARD DETAIL LANDSCAPE CONSTRUCTION DETAIL

OFFSET WALL 600mm FROM

THE EDGE OF THE PATH

RECONSTRUCT THE FIRST

3.0m OF STONE WORK

**RECONSTRUCTED STONE WALL AND PATH DETAIL** 

DWG NO.

**SDL.8.01** 

REVISION\_A